

Project:

Order No: Premio EPS80 Compression

Part No: P80/2018_08_09


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2018. 08. 09. 9:23:09

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
P80/2018_08_09 (2)	78,52	10,00
P80/2018_08_09 (4)	81,39	10,00
P80/2018_08_09 (5)	79,70	9,99
P80/2018_08_09 (9)	83,16	10,00
Max.	83,16	10,00
Min.	78,52	9,99
Mean	80,69	10,00