

Project:

Order No: Premio EPS80 Compression test

Part No: P80/2021_05_14


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 05. 14. 11:44:27

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2021_05 _14(1)	91,21	9,99
Premio EPS80/2021_05 _14(2)	88,89	10,00
Premio EPS80/2021_05 _14(3)	89,17	9,99
Premio EPS80/2021_05 _14(4)	89,87	9,99
Max.	91,21	10,00
Min.	88,89	9,99
Mean	89,79	9,99