

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2021_07_05(1)


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 07. 05. 13:31:19

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2021_07_05(1)	85,23	10,00
Premio EPS80/2021_07_05(2)	80,15	9,99
Premio EPS80/2021_07_05(3)	83,93	9,99
Max.	85,23	10,00
Min.	80,15	9,99
Mean	83,10	9,99