

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2021_12_10


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2022. 12. 10. 17:23:32

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2021_12_10(4)	84,40	9,99
Premio EPS80/2021_12_10(6)	79,14	9,99
Premio EPS80/2021_12_10(7)	82,86	9,99
Max.	84,40	9,99
Min.	79,14	9,99
Mean	82,14	9,99