

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2022_03_10


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2022. 03. 10. 11:16:13

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2022_12 _19/1.1(1)	93,38	9,99
Premio EPS80/2022_12 _19/1.1(3)	95,55	9,99
Premio EPS80/2022_12 _19/1.1(5)	92,85	9,99
Max.	95,55	9,99
Min.	92,85	9,99
Mean	93,93	9,99