

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2022_08_10


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2022. 08. 10. 14:46:05

Chart:



Results:

Nom	Stress [kPa] ,max.	
Premio EPS80/2022_08 _10/T5(1)	86,35	
Premio EPS80/2022_08 _10/T5(2)	81,79	
Premio EPS80/2022_08 _10/T5(3)	82,47	
Max.	86,35	0
Min.	81,79	0
Mean	83,54	0