


Project:

Order No: Premio EPS100 Compression test
Part No: Premio EPS100/2022_12_09
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2022. 12. 09. 8:36:00

Chart:



Results:

Nom	Stress [kPa] ,max.	
Premio EPS100/2022_12_09(5)	102,28	
Premio EPS100/2022_12_09(6)	100,11	
Premio EPS100/2022_12_09(8)	99,60	
Max.	102,28	0
Mean	100,66	0