


**Project:**

Order No: Premio EPS100 Compression test  
Part No: Premio EPS100/2023\_01\_10  
Customer: Premio Hungária

Tester: Thümler GmbH-Z5  
Method: MSZ EN 826  
Execution date: 2023.01.10. 8:51:41

**Chart:**



**Results:**

| Nom                            | Stress [kPa]<br>,max. |   |
|--------------------------------|-----------------------|---|
| Premio<br>EPS100/2023_01_10(1) | 104,47                |   |
| Premio<br>EPS100/2023_01_10(2) | 100,93                |   |
| Premio<br>EPS100/2023_01_10(4) | 104,87                |   |
| Max.                           | 104,87                | 0 |
| Mean                           | 103,42                | 0 |