

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80 /2023_05_02


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2023. 05. 02. 11:30:45

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80 /2023_05_02(1)	89,11	9,99
Premio EPS80 /2023_05_02(2)	83,59	9,99
Premio EPS80 /2023_05_02(3)	85,46	10,00
Mean	86,05	9,99