


Project:

Order No: Premio EPS100 Compression test
Part No: Premio EPS100 2023_07_07
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2023.07.07. 11:54:19

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS100_2023_0 7_07	103,49	9,99
Premio EPS100_2023_0 7_07	104,87	10,00
Premio EPS100_2023_0 7_07	105,34	10,00
Mean	104,57	10,00